

TECHNICAL CONSIDERATION (NOT FOR FIELD REPRESENTATIVE'S USE):

These products are not intended to function as lightning arresters. The effect of these products on connected equipment and the adequacy of the voltage-suppression level to protect connected equipment from transient voltage surges have not been evaluated.

Use - For use only in (or with) complete equipment, where the acceptability of the combination is determined by UL LLC.

CONDITIONS OF ACCEPTABILITY:

1. The MLV given for the components in this Report are for reference only and cannot represent the VPR of an end-product, as final installation, construction, and internal wiring of an end-product may affect the VPR significantly.
2. Type 5 only devices were not subjected to the Limited Current Abnormal Overvoltage Test as required by Section 39.4 of the UL 1449. The suitability of these devices to comply with these tests in the end-use application shall be determined.
3. These devices have not been subjected to the SCCR and Intermediate Current Testing as required by Section 39.2 and 39.3 of UL 1449. The suitability of these devices to comply with these tests in the end-use application shall be determined. With regards to Intermediate or SCCR Current testing, if the integral thermal responsive device opens during this testing the test needs to be conducted two more times and subjected to follow-up testing in the end-use application.
4. These devices have been investigated for use inside a suitable overall enclosure. The suitability of these devices to function as an overall enclosure has not been determined and needs to be considered in the end-use application.