

TECHNICAL CONSIDERATIONS (NOT FOR FIELD REPRESENTATIVE'S USE):

Use - For use only in (or with) complete equipment, where the acceptability of the combination is determined by UL LLC.

CONDITIONS OF ACCEPTABILITY:

1. The MLV given for these Type 5 SPD's in this Report are for reference only and are not representative of a VPR rating when used in an end-product, as final installation, construction, and internal wiring of an end-product may affect the VPR.
2. Type 5 SPDs have not been subjected to the SCCR and Intermediate Current Testing as required by UL 1449. The suitability of these devices to comply with these tests in the end-use application shall be determined.
3. Type 5 SPDs have not been subjected to the Limited Current Abnormal Overvoltage Test as required by UL 1449. The suitability of these devices to comply with these tests in the end-use application shall be determined.
4. The output wire is colored as black with orange stripe. For proper installation, ensure the device is installed in this manner.
5. These components are provided with min 6 inch pigtail (flying) leads and are suitable for field wiring.
6. These components are to be housed within a suitable enclosure in the end product installation.
7. **Remote signal wiring shall only be used with Class 1 circuits only.**